



14 Julius Avenue, North Ryde NSW 2113
PO Box 52, North Ryde NSW 1670, Australia
T (02) 9490 5444 • ABN 41 687 119 230

Certificate of Assessment

HF07ANK5567

No. 990

"Copyright CSIRO 2007 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Manufacturing and Materials Technology in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

DuPont Australia Ltd.
168 Walker Street
NORTH SYDNEY NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 8910.

SAMPLE IDENTIFICATION: Corian Sheet

DESCRIPTION OF SAMPLE: The sponsor described the tested specimen as a mineral-filled polymethymethacrylate sheet.

Nominal total thickness: 12 mm
Nominal specific gravity: 1.6-g/cm³ to 1.8-g/cm³
Colours: various

SAMPLE CLASSIFICATION: Group Number: Group 3
(In accordance with Specification A2.4 of the Building Code of Australia.)
Average specific extinction area: 13.9 m²/kg
(Refer to Specification C1.10a section 3(c) of the Building Code of Australia.)

Testing Officer: Russell Collins Date of Test: 13 June 2007

Issued on the 26th day of June 2007 without alterations or additions.

Garry E Collins
Manager, Fire Testing and Assessments



This laboratory is accredited (Accreditation No. 165, Corporate site No.3625) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.